

# Confirmation

## LEED

On 27 March 2017, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

### **ResiFix VYSF**

supplied by

### **CELO Befestigungssysteme GmbH**

The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2017-00105907\_H\_EN\_23 and 392-2017-00106007\_XD\_EN\_23).

**The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of SCAQMD rule 1168 (2005)

18 September 2020



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.